


PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

CERTIFICATE NO DATED:

89/camp/lab-1, 27/06/2025

It is certified that an inspection team headed by **Assistant Engineer, Shashank Pandey** from U.P. Jal Nigam Gorakhpur inspected the **Gurukul Public School, Harpur, Pepeganj, Gorakhpur**, on 23/06/2025 and on the basis of Water Test Report (Attached) bearing no **89/camp/lab-1** dated **27/06/2025** of District Water Analysis Laboratory Jal Nigam Gorakhpur (PHED Lab) certified that the **Gurukul Public School, Harpur, Pepeganj, Gorakhpur**, has safe drinking water facilities for the students and members of staff of the institution as per the norms prescribed by the Central/ State/ U.T. Govt.


This certificate is valid till: **27/06/2025 to 27/12/2025**




Name:- **Shashank Pandey**
Assistant Engineer
U.P. DIVISION U.P. Jal Nigam
GORAKHPUR

Designation:- **Assistant Engineer**

To,
Manager
Gurukul Public School, Harpur, Pepeganj
Gorakhpur, 273165


Manager
Gurukul Public School
Harpur, Pepeganj, GK:


PRINCIPAL
GURUKUL PUBLIC SCHOOL
HARPUR, PEPPEGANJ



Regional Water Testing Laboratory (Uttar Pradesh Jal Nigam, Gorakhpur)

Address: EWS 388,389,390 Rapti Nagar Phase-1, Medical Road,
Gorakhpur(U.P)-273003



TC-12931

CHEMICAL SAMPLE TEST REPORT

Rept. No: **89** /Camp / Lab-1 Date: 27/06/2025 Page No: _____

Customer Details

Office Name and Address: Gurukul Public School, Harpur Pepeganj, Gorakhpur
Ref Letter No & Date: 23/06/2025

Basic details of sample

District	Gorakhpur	Block	--
Gram Panchayat	--	Village	--
Habitation	--	Location	Gurukul Public School, Ward No 08 Harpur, Nagar Panchayat Pepeganj, Gorakhpur
Water Source	R.O	Sample Code	(C/25/06/57)
Quantity of Sample	1000ml	Date of S.C.	24/06/2025
Receiving Date	24/06/2025	S. Collector	Mritunjay Nishad
Sample Depositor	Mritunjay Nishad		
Analysis Start Date	25/06/2025	Analysis Completion Date	26/06/2025

Environmental Condition

Temperature: 26.2 °C Relative Humidity: 56%

Technical Data of Analysis

Sr. No	Analyzed parameters (Unit of Measurement)	Observed Value	Unit	Specified Values as per BIS 10500:2012		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	Odour	Agreecable				IS 3025 (Part 5):2018
2	Turbidity	0.20	NTU	1	5	IS 3025 (Part 10):2023
3	pH (25°C)	7.97	--	6.5-8.5	No relaxation	IS 3025 (Part 11):2022
4	Total Dissolved Solids	102	mg/L	500	2000	IS 3025 (Part 16):2023
5	Total Hardness	68	mg/L	200	600	IS 3025 (part 21):2023
6	Total alkalinity	92	mg/L	200	600	IS 3025(Part 23):2023
7	Chloride as Cl	24	mg/L	250	1000	IS 3025(Part 32):2003
8	Calcium	17.6	mg/L	75	200	IS 3025(Part 40): 2024
9	Magnesium	3.889	mg/L	30	100	IS 3025(Part 46): 2023
10	Sulphate	3.472	mg/L	200	400	APHA 24th Edition 4500-SO ₄ Method E Turbidimetric Method 2023
11	Nitrate	0.168	mg/L	45	No relaxation	APHA 24th Edition 4500-NO ₃ Method B UV Screening Method 2023
12	Iron	0.022	mg/L	1	No relaxation	APHA 24th Edition 3500-Fe Method B Phenanthroline Methods 2023
13	Fluoride	0.01	mg/L	1.0	1.5	APHA 24th Edition 4500-F Method C (Electrode Method):202300
14	Arsenic	BDL	mg/L	0.01	No Relaxation	APHA 24th Edition 3500 Method B (Silver Diethyldithiocarbamate Method)

#BDL- Below Detection Limit, NA- Not Analyzed

** Parameter(s) above permissible limit are in bold digits.

- Note
1. This Certificate refers only to the particular sample(s) submitted for testing.
 2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has.
 3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
 4. Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of tests reports unless.
 5. Sample not collected by the laboratory.

Received By: *[Signature]*

[Signature]
Manager
Gurukul Public School
Harpur, Pepeganj, Gorakhpur

[Signature]
PRINCIPAL
GURUKUL PUBLIC SCHOOL
HARPUR, PEPPEGANJ

[Signature]
Authorized Signatory

Laboratory Contact details: Harpur, Pepeganj, Gorakhpur

Contact - +91 8604561988

End of Report

